



## WATER SUPPLY SOURCES

CITY OF LACONIA FIRE PREVENTION DIVISION  
848 NORTH MAIN STREET, LACONIA, NH 03246

Call (603) 524-6881 for appointments and information

**FIRE PREVENTION**  
**Fire Department**  
**Access and Water Supply**  
**800-1**  
May 2025

An adequate water supply is critical to fire department operations. Therefore, the following are acceptable sources of water supply:

1. Hydrants connected to City of Laconia Water Works water system
  - a. All new sub-divisions in excess of four units and all other types of buildings with access to the Water Works system.
2. For areas not served by Laconia Water Works, the following water supply sources are acceptable:
  - a. Underground water cistern
    - i. Specifications can be found in Fire Prevention Regulation 800-2
  - b. Dry hydrant
    - i. Specifications can be found in Fire Prevention Regulation 800-3
  - c. Install automatic fire sprinklers in all properties/buildings
    - i. Specifications can be found in Fire Prevention Regulations Section 500 and applicable NFPA codes.

The AHJ has the authority to make the final determination, based on NFPA standards, as to what is required for water supply.

**Source:** City of Laconia Ordinances Chapter 149-13.4 Water supply

